

In view that the clarifications sought by the prospective bidder, could be uploaded today only; date of opening of technical bids is extended to 16.03.2020 to allow all bidders to bid accordingly in view of the revised specifications as per clarifications given by the user department.

Ambedkar University Delhi

Karampura Campus

06.03.2020

Item no. 1 ~~Capacity of deep fat Fryer in litres needs to be mentioned.~~

Suggestion: 2 Nos Deep Fat fryer is required (4 litre oil capacity & 6 litre oil capacity)

Item no. 2 Thickness and colour of marble to be mentioned.

Suggestion: 1.5cm to 2cm of width & smoky black colour *جراحی تاپ*.

Item no. 4 whether this item is dough Kneader or bakery mixer- to be clarified.

Suggestion: Need to be used for both with different accessories as per requirement.

Item no. 5 Two brands mentioned in item no. 5 manufacture commercial machine and other two manufacture domestic machine need to be clarified whether commercial machine is required or domestic one.

Suggestion: Rational commercial oven required of 6 trays.

Item no.8 Specifications mentioned in item no.8 are available in customized local make and not in Godrej/Kaff. So may be removed brand name Godrej/ Kaff.

Suggestion: Item No 8 has to be in alignment with Item No 30 & 31

Item no.10 Suggested to remove wattage i.e. 1090W


Suggestion: Can be from a range of 1000W - 1500W.

Item no.14 This has to be customized as exhaust hood and therefore brand name Kaff to be removed.

Suggestion: Exhaust hood to be of best brands like Godrej/ Glen.

Item no. 16 Size of Tandoor Hood in L x B x H to be mentioned. Kaff does not manufacture.


Suggestion: Size should be able to cover both Tandoor and Chinese Range for best smoke removal from the kitchen.



- Item no. 17** To be clarified whether commercial model is required or domestic one.  
Suggestion: Commercial Model
- Item no.18** Warranty of Milti Tandoor may be reduced to one year.  
Suggestion: As per previous requirement only maintainace is required.
- Item no.19** Suggested to remove weight of the machine to make this more generic. Suggested to add brand Sirman/Robot Cut or equivalent.  
Suggestion: Mentioned requirement is the production capacity and not the weight of machine.
- Item no.21** Brand Voltas may be removed and equivalent may be added.  
Suggestion: Equivalent brand like IFB & Bosch may be added.
- Item no.22** Suggested to add brand Euronics or equivalent.  
Suggestion: Equivalent brand like Awoco/ Yoshimasha /Welbon may be added.
- Item no. 24** Vendor could not identify this item. Needs clarification.  
Suggestion: Water fountain basin for less hand touch and maintain hygiene.
- Item no.26** Whether commercial model is required or domestic one.  
Suggestion: Commercial Model
- Item no.28** Suggested that for 2 litres blender 3 HP motor is not required and hence may be removed from specifications.  
Suggestion: Regular usage of the product is required so the same motor is required.
- Item no.30 and 31** Size in terms of L x B x H is required.

as per detail below supplied by godrej

334

A	<p>Sub Head: Modular kitchen -Under storage cabinets</p>
1	<p>Providing &amp; placing Factory made modular Kitchen cabinets of Godrej or equivalent make with openable shutters and sufficient number of drawers made of 0.6mm body panels &amp; 1.2mm thick horizontal Frames of Galvanised sheet with zero spangle(as per ASTM A653), components shall be powder coated with high quality powders like Dupont, Kanasai Nerolac with dry film thickness of 40 to 60 microns with pencil hardness of 2H Min. It also includes the Tall unit of 2000 mm height.All shelves shall be supported on approved quality SS pins and shall be adjustable for different heights as per requirements.Shutters to be at least 18mm thick in Galvanisheet steel . Each shutter shall be fixed to the framework/carass using two numbers of best quality CED coated hinges ( Blum, Hettich approved make) i/c soft/Auro closing hinges as per requirement(Hettich make or equivalent) fixed with SS screws , nails etc complete and these shutters are provided with an approved quality of Godrej Arc 128 mm pitch. Finished components shall be tested for the critical quality parameters .Adhesion and impact test which enhances the life of kitchen.Shelves to be of galvanised steel sheet with thickness of 12 mm with even wire basket in grade 304 SS. Steel carcass and shutters shall have passed the test like Static Load test,Shelf deflection test.Modular kitchen accessories (Godrej or equivalent make, payment for which will be made separately) to be fixed in the drawer/Cabinet with suitable provision with panels of bottom and rear shelves with thickness of 0.6mm as per technical requirement. Tall units will be supported by units will be supported by 100mm height vertical adjustable legs (Hettich or equivalent approved) which will be covered with PVC skirting (Rehau or equivalent make ) in brushed aluminium finish attached by hardware of skirting . The unit shall be fixed to the floor/ wall/slab using metal screws of appropriate size and rawl plugs . The work shall be executed as per drawing/Sample prepared in sample flat at site and direction of Engineer-in-charge. Only face area of openable shutter and drawer shall be measured for payment. Cabinet with depth of 560mm(Approx).</p>
B	<p>Sub Head: Modular Kitchen : Tall Unit</p>
1	<p>Providing &amp; placing factory made modular kitchen of Godrej or equivalent make having Tall Unit with openable shutters and 1.2mm thick horizontal Frames of Galvanised sheet with zero spangle(as per ASTM A653), components shall be powder coated with high quality powders like Dupont, Kanasai Nerolac with dry film thickness of 40 to 60 microns with pencil hardness of 2H Min. The height of unit is 2000 mm.</p> <p>All shelves shall be supported on approved quality SS pins and shall be adjustable for different heights as per requirements.Shutters to be at least 18mm thick in Galvanisheet steel . Each shutter shall be fixed to the framework/carass using two numbers of best quality CED coated hinges ( Blum, Hettich approved make) i/c soft/Auro closing hinges as per requirement(Hettich make or equivalent) fixed with SS screws , nails etc complete and these shutters are provided with an approved quality of Godrej Arc 128 mm pitch. Finished components shall be tested for the critical quality parameters .Adhesion and impact test which enhances the life of kitchen.Shelves to be of galvanised steel sheet with thickness of 12 mm with even wire basket in grade 304 SS. Steel carcass and shutters shall have passed the test like Static Load test,Shelf deflection test.Modular kitchen accessories (Godrej or equivalent make, payment for which will be made separately) to be fixed in the drawer/Cabinet with suitable provision with panels of bottom and rear shelves with thickness of 0.6mm as per technical requirement. Tall units will be supported by 100mm height vertical adjustable legs (Hettich or equivalent approved) which will be covered with PVC skirting (Rehau or equivalent make ) in brushed aluminium finish attached by hardware of skirting . The unit shall be fixed to the floor/ wall/slab using metal screws of appropriate size and rawl plugs . The work shall be executed as per drawing/Sample prepared in sample flat at site and direction of Engineer-in-charge. Only face area of openable shutter and drawer shall be measured for payment. Cabinet with depth of 560mm(Approx).</p>
C	<p>Sub Head- Kitchen Accessories,</p> 

1

Providing and fixing Utensil Kit of Godrej Make of size 900mm in 304 SS grade i/e a set of 2 palin SS wire baskets 150 mm with required SS screw for fixing above component of godrej make or quivalent, complete as per drawing in the existing space, sample prepared in sample flat at site and direction of Engineer-in-charge.